



NOTES:

1. WRAP ALL BELOW GRADE SCH 40 BRASS WITH UPC 10 MIL BLACK "PIPE WRAP".
2. ATTACH PURPLE RECYCLED IDENTIFICATION TAGS AS DIRECTED ON RECYCLED WATER SYSTEMS.
3. ATTACH GREEN POTABLE WATER USED FOR IRRIGATION IDENTIFICATION TAGS AS DIRECTED ON POTABLE IRRIGATION SYSTEMS.
4. VALVE BOX LID SHALL BE BRANDED TO IDENTIFY VALVE. SEE DETAIL IRR-24.
5. ATTACH ID TAGS WITH #14 UF WIRE OR ZIP TIE.
6. USE DIELECTRIC COUPLINGS ON ALL GALVANIZED STEEL PIPING BETWEEN UNION AND DOWNSTREAM PIPING
7. VALVE BOXES SHOULD REST ON A 1/2" ROUND GRAVEL SUMP, 12" SQUARED.
8. GRAVEL SUMP MUST BE INSTALLED FIRST.
9. BOLTDOWN VALVE BOX COVER WITH STAINLESS STEEL BOLT AND WASHER.
10. USE PURPLE RECYCLED WATER IDENTIFICATION BOXES AND COVER FOR RECYCLED SYSTEMS.
11. MINIMUM DISTANCE FROM TOP OF VALVE ASSEMBLY TO BOTTOM OF VALVE COVER SHALL BE 3 INCHES.
12. ATTACH PURPLE RECYCLED WATER IDENTIFICATION TAPE TO ALL BRASS PIPING AS DIRECTED ON RECYCLED WATER SYSTEMS.
13. ATTACH GREEN POTABLE WATER, USED FOR IRRIGATION, IDENTIFICATION TAPE TO ALL BRASS PIPING AS DIRECTED ON POTABLE IRRIGATION SYSTEMS.

MOULTON NIGUEL WATER DISTRICT

MASTER CONTROL VALVE

IRR-8