

**NOTES:**

1. VALVE BOX LID SHALL BE BRANDED TO IDENTIFY QUICK COUPLER "SEE BRANDING DETAIL".
2. ATTACH RECYCLED WATER IDENTIFICATION TAGS OR POTABLE WATER USED FOR IRRIGATION IDENTIFICATION TAGS AS DIRECTED BY THE DISTRICT.
3. ACME THREAD PIPE TYPE QUICK COUPLING VALVE FOR RECYCLED WATER USE
4. PIN LOCK TYPE QUICK COUPLING VALVE FOR POTABLE WATER USE
5. BOLTDOWN VALVE BOX COVER WITH STAINLESS STEEL BOLT AND WASHER.
6. USE PURPLE RECYCLED WATER IDENTIFICATION BOXES AND COVERS FOR RECYCLED SYSTEMS.
7. FOR SCH 40 GALVANIZED PIPING CONTACT MNWD.
8. MINIMUM DISTANCE FROM TOP OF QUICK COUPLING VALVE TO BOTTOM OF VALVE COVER SHALL BE 3 INCHES.
9. ATTACH PURPLE RECYCLED WATER IDENTIFICATION TAPE TO ALL PIPING AS DIRECTED ON RECYCLED WATER SYSTEMS.
10. ATTACH BLUE POTABLE WATER IDENTIFICATION TAPE TO ALL BRASS PIPING AS DIRECTED ON POTABLE WATER SYSTEMS.
11. ATTACH GREEN POTABLE WATER, USED FOR IRRIGATION, IDENTIFICATION TAPE TO ALL PIPING AS DIRECTED ON POTABLE IRRIGATION SYSTEMS.

