



NOTES:

1. WRAP ALL BELOW GRADE SCH 40 GALVANIZED STEEL WITH UPC 10 MIL BLACK "PIPE WRAP" AND IDENTIFICATION TAPE AS DIRECTED BY THE DISTRICT.
2. ATTACH PURPLE RECYCLED IDENTIFICATION TAGS AS DIRECTED ON RECYCLED SYSTEM.
3. ATTACH GREEN POTABLE WATER, USED FOR IRRIGATION, IDENTIFICATION TAGS AS DIRECTED ON POTABLE IRRIGATION SYSTEMS.
4. VALVE BOX LID SHALL BE BRANDED TO IDENTIFY VALVE (SEE "BRANDING DETAILS" IRR-24).
5. ATTACH ID TAGS WITH #14 UF WIRE OR ZIP TIE.
6. USE DIELECTRIC COUPLINGS ON ALL GALVANIZED STEEL PIPING BETWEEN UNION AND LATERAL LINE.
7. VALVE BOXES SHOULD REST ON A GRAVEL SUMP. 12" SQUARED.
8. GRAVEL SUMP MUST BE INSTALLED FIRST.
9. BOLTDOWN VALVE BOX COVER WITH STAINLESS STEEL BOLT AND WASHER.
10. USE PURPLE RECYCLED WATER IDENTIFICATION BOXES AND COVER FOR RECYCLED SYSTEM.
11. ALL MAINLINE AND REMOTE CONTROL VALVE FITTINGS SHALL BE SCH 80.
12. MINIMUM DISTANCE FROM TOP OF VALVE ASSEMBLY TO BOTTOM OF VALVE COVER SHALL BE 3 INCHES.
13. FOR SCH 40 GALVANIZED PIPING CONTACT MNWD.

MOULTON NIGUEL WATER DISTRICT	IRR-10
REMOTE CONTROL VALVE	