



NOTES:

1. ALL RING-TITE OR SOLVENT WELDED PLASTIC PIPE TO BE INSTALLED ACCORDING TO THESE DETAILS UNLESS OTHERWISE NOTED OR DETAILED AS DIRECTED BY MNWD.
2. PORTLAND CEMENT CONCRETE USED FOR THRUST BLOCKS SHALL BE 420-C-2000 CONCRETE.
3. ALL ANCHOR RODS SHALL BE GALVANIZED STEEL, MINIMUM 1/2 INCH DIAMETER, WRAPPED AROUND PIPE.
4. SIZE OF THRUST BLOCKS SHALL BE SPECIFIED ON PLANS OR AS DIRECTED BY MNWD.
5. ALL VIEWS ARE PLAN VIEW UNLESS OTHERWISE NOTED.
6. THRUST BLOCKS REQ'D ON LINE SIZES 2" OR GREATER OR AS REQ'D BY MNWD.