

NOTES:

1. BUNDLE & LOOSELY TAPE WIRING AT 10' INTERVALS USING UL APPROVED BLACK ELECTRICAL TAPE.
2. TIE A LOOSE 24" LOOP IN WIRING EVERY 100 FEET AND AT CHANGES OF DIRECTION GREATER THAN 30°. UNTIE ALL LOOPS AFTER ALL CONNECTIONS HAVE BEEN MADE.
3. INSTALL ALL CONTROL WIRE ON THE UNDERSIDE OF THE MAIN LINE PIPE.
4. MEET LOCAL CODE REQUIREMENTS FOR BACKFILL & COMPACTION REQUIREMENTS.
5. PIPE COVER FOR PRESSURE MAINLINES SHALL BE A MINIMUM OF 18", 24" OR 36" AS DETERMINED BY MNWD.
6. PIPE COVER FOR NON-PRESSURE LATERAL LINES SHALL A BE MINIMUM 12" OR 18" FOR SPRAY HEADS.
7. PIPE COVER FOR NON-PRESSURE LATERAL LINES SHALL BE A MINIMUM 12" OR 18" FOR ROTOR HEADS.
8. COMMON TRENCH WITH OTHER UTILITIES OR PIPING IS PROHIBITED.
9. PIPING CLASSIFICATIONS AND ASTM APPROVALS SHALL BE PLACED IN THE UPRIGHT POSITION FOR ALL PIPING.

