

APPENDIX 8

MOULTON NIGUEL WATER DISTRICT

Requirements to install potable water and recycled water pipelines prior to the placement of curb and gutter.

1. All requirements shall be met before the excavation of pipeline trenches.
2. The owner is to submit engineered drawings showing both the plan and profile of the proposed pipelines for District review and acceptance.
3. The owner is to provide survey staking. The proposed pipelines per the profile with cuts to flow line at a maximum of 25-foot stationing. Showing all horizontal and vertical grades breaks, tees, and valves, fire hydrant, blow-offs, air vacs, services, and all other appurtenances indicated on the plans.
4. Prior to backfill, the engineer shall certify line and grade and all the appurtenances and provide the District inspector with a copy of the certification.
5. In the event that a portion or any part of the pipeline and its appurtenances is not installed to the satisfaction of the District inspector, the owner agrees to expose and re-lay the pipeline accordingly.

I hereby agree to the above mentioned requirements

Owner/Owner's Representative_____

Address_____

Name/Signature_____

Phone Number_____

Project Name_____

Engineer of Record_____